

NR 445 Technical Advisory Group

Proposal For Control Of Emissions From Compressed-Ignition Internal Combustion Engines Combusting Fuel Oil

April 16, 2002

Caroline Garber, 608-264-9218

garbec@dnr.state.wi.us

Jeff Myers, 608-266-2879

myersj @dnr.state.wi.us

Andrew Stewart, 608-266-5499

stewaa @dnr.state.wi.us

Bureau of Air Management



Purpose

- ◆ To Lay Out & Explain Basis For Proposed Emission Limits For Existing Engines Combusting Greater Than 40,000 GPY Fuel Oil.
- Provide Additional Information On What Constitutes A Modified Engine



What Level Of PM Control Would Be Required?

- ◆ 100-750 Hp engines
 - ◆ 0.10 g/bhp-hr
- → >750 Hp engines
 - ◆ 0.03 g/bhp-hr

Diesel proposal April 2002.ppt

NR 445 Technical Advisory Group



How Would Compliance Be Demonstrated?

- ◆ Individual Engine(s):
 - Equip with a device certified by California Air Resources Board, the US EPA, or as approved by DNR using equivalent test method
 - Submit compliance certification to the DNR



How Were The Emission Rates Chosen?

- ♦ Review of Available Information On Retrofit Technologies
 - Government Agencies
 - Control Product Manufacturers
 - Diesel Technology Organizations
 - Academic Literature
 - Industries Reliant on Diesel Technology
- Reviewed Test Results
 - California Air Resources Board
 - Manufacturers of Emission Control Association




How Were The Emission Rates Chosen?

- ◆ Levels reflect an approximate 80-90% reduction from baseline
 - ◆ Combination of low sulfur fuel & PM controls
 - ◆ Baseline established using EPA's AP-42
- Supportable by technology available today
 - Numerous examples of successful retrofit technology
 - Growing number of certified control devices

April 16, 2002

		75% Reduction From Baseline		90% Reduction From Baseline	
	Existing	30 ppm	g/bhp-hr	30 ppm + control	g/bhp-hr
HP	(lbs/hr)	(lbs/hr)		(lbs/hr)	0 1
50	0.11	0.03	0.25	0.01	0.10
100	0.22	0.06	0.25	0.02	0.10
250	0.55	0.14	0.25	0.06	0.10
500	1.10	0.28	0.25	0.11	0.10
1000	0.70	0.18	0.08	0.07	0.03
1500	1.05	0.26	0.08	0.11	0.03
2000	1.40	0.35	0.08	0.14	0.03
2500	1.75	0.44	0.08	0.18	0.03



2.20E-03 lbs/bhp-hr power output 0.22 lbs/hr (100 Hp) **0.999 grams/bhp-hour**

0.31 lbs/mmBTU fuel input 0.22 lbs/hr (100 Hp)

AP-42 for large (600 Hp and greater) stationary source ICE (NOx control by ignition timing retard)

7.00E-04 lbs/bhp-hr power output 0.42 lbs/hr (600 Hp) **0.318 grams/bhp-hour**

0.10 lbs/mmBTU fuel input 0.42 lbs/hr (600 Hp)

1 kilowatt = 3415 btu/hour Fuel

 1 horsepower = 0.7457 kilowatts
 140,000 btu/gal


 1 kilowatt = 1.341 horsepower
 19,200 btu/lb

 1 horsepower = 2547 btu/hr (100% efficient)
 7.3 lbs/gal

1 horsepower = 7000 btu/hr (36% efficient)

Diesel proposal April 2002.ppt

NR 445 Technical Advisory Group





How Will Modifications Be Determined?

- ◆ An engine is considered to be modified, and therefore subject to BACT requirements, when:
 - ◆ A physical change or change in the method of operation results in an increase in emissions above an allowed increment (criteria pollutant specific)
- ◆ Repairing or rebuilding will not trigger a modification if it is considered to be routine maintenance or repair.
- ◆ Single repair costs exceeding 50% of new engine may be considered to be a modification.